

Fire and Rescue Services Department
No Objection Certificate

No.:64/ 2025

R.C.No:533 /V /2025

Date: 11.12.2025

Fire and Rescue Services Station
Chidambaram

Certified that the R.S. No. 43/9, 12, 59/1, 3, 60/2, 3A, 3B, 60/4, 66/5B1, 66/5B2, 66/5A1, A2 at Mutlur Bypass Road, Thillainayagapuram, Keezhamoongiladi (PO), Chidambaram Taluk comprised of Ground Floor basement and Two (upper Floors) owned / occupied by **OXFORD ENGLISH SCHOOL** have complied with the fire prevention and fire safety requirements in accordance with rule of State / UT Fire Service Rules, and verified by **P.MANIMARAN** Station officer, Chidambaram on 12.12.2025(date of inspection) in the Presence of The Correspondent and that the building / premises is fit for occupancy **CLASS LKG TO XII** effect from 12.12.2025 for a period of 3 years in accordance with rule and subject to compliance of the conditions.

Issued on 12.12.2025 at Chidambaram by Station Officer

Conditions:

1. Regular Licence has to be obtained from competent authority.
2. If there is any deviation from the Government Rules and Act, the licence issued will be Cancelled.
3. All the Extinguishers have to be recharged and maintained periodically as per code practice in 2190:2010.
- 4.Hose Reel Hose Assembly Should be Provided
5. National Building code:2016 Fire and Life Safety part-IV should be followed.

(Office Seal with Date)



Signature with seal

(Signature)
12.12.25
STATION OFFICER,
Fire - Rescue Station,
CHIDAMBARAM-608 001

Name : **Mr.P.MANIMARAN**

To

THE CORRESPONDENT
OXFORD ENGLISH SCHOOL
Thillainayagapuram village,
Chidambaram – 608 602..